



# Attestation of Conformity

## Unscreened Category 5e ISO/IEC, EN & TIA/EIA Connecting Hardware

**Reichle & De-Massari Identifications**  
**P/N R925371, R304326, R302518, R308733 and R305112**

**Category 5e, Unscreened, Modular Jack**  
**Electrical Transmission Performance**

**Reichle & De-Massari AG**  
**Binzstrasse 31**  
**CH-8622 Wetzikon, Switzerland**

*Attestation of Conformity No. 109674*

*This Unscreened ISO/IEC, EN & TIA/EIA Connecting Hardware having preformed inlay conductors has been tested by 3P Third Party Testing and complies with the Category 5 transmission requirements of 2<sup>nd</sup> edition ISO/IEC Generic Cabling Standard 11801 and CENELEC Generic Cabling Standard EN 50173-1:2007, and the Category 5e transmission requirements of ANSI/TIA Generic Cabling Standard 568-C.2 and IEC Connecting Hardware Standard 60603-7-2. The requirements are passed using the total range of re-embedded vectors specified in ANSI/TIA-568-C.2 and draft IEC 60512-27-100. The Attestation of Conformity is valid for the actually tested connecting hardware samples and no verification of the running production is performed.*

Hoersholm, 27<sup>th</sup> October 2009

*Ole Lambertsen*

Ole Lambertsen  
Test Responsible

Hoersholm, 27<sup>th</sup> October 2009

*Poul Villien*

Poul Villien  
Coordinating Manager