



Attestation of Conformity

Unscreened Class E / Category 6 ISO/IEC, EN & ANSI/TIA Two Connector Permanent Link

**Krugel Exim spol. s.r.o.
Pri majeri 13,
831 06 Bratislava, Slovak Republic**

Attestation of Conformity No. 0473-3P-1231074

This type of Class E / Category 6 Unscreened Two Connector Permanent Link has been tested by 3P Third Party Testing. The testing has shown compliance with the Class E electrical performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018 and the Category 6 electrical performance requirements of ANSI/TIA-568.2-D:2018. The Attestation of Conformity is valid for the actually tested permanent link sample at the time of testing. The positive observations and test results that are the basis for this Attestation of Conformity, are relevant only to the tested sample and do not imply that the product is, or has ever been, under a 3P maintenance programme.

<i>Cables:</i>	<i>Horizontal Cable (30 - 90 m), Qualification Status:</i>	<i>P/N KE400U23LSOH-XXX Manufacturer verified</i>
<i>Conn. Hardware:</i>	<i>Modular Jack, Qualification Status:</i>	<i>P/N KEJ-C6-U-TL PCB marking: 1021C6 119 2248 Manufacturer verified</i>

Hoersholm, 26 September 2023


Peter Freiberg Kaas
Test Responsible

3P Third Party Testing ApS
Agern Alle 3
2970 Hørsholm
Denmark

<https://www.3ptest.dk/>

Hoersholm, 26 September 2023


Jens Rytter Petersen
General Manager